

Er. D.NATARAJAN, B.E.(CIVIL),M.I.E.,  
CHARTERED ENGINEER  
REGISTERED & APPROVED ENGINEER  
BY THE BOARD OF ENGINEERS, TAMIL NADU.  
PANEL ENGINEER CLASS IA, THIRUVANNAMALAI DISTRICT  
TVMalai Collector, Reg. No. ந.க.டி. 321824/2012 dated 03.01.2013

Res: 50-A,3<sup>rd</sup> Street, S.S.Nagar.  
Palanipet, Arakkonam – 631002  
Off: 400, Nethaji Bose 4<sup>th</sup> Street  
Phase III, TNHB, Sathuvachari  
Vellore – 632 009  
Cell: 9443106470, 8056631312  
Email: dnatarajan8@gmail.com


**STRUCTURAL SOUNDNESS CERTIFICATE RELATING TO SCHOOL**  
**STATEMENT ACCOMPANYING FORM - A**

1. Name of the School and Door no of the Building : **WISDOM VIDHYASHRAM INTERNATIONAL SCHOOL**  
Arcot Road, Painginar Village, Cheyyur Taluk  
Tiruvannamalai District - 604407.
2. Location (street No. Ward No. Name of place, ie., Corporation, Municipality/ Panchayat Union/ Panchayat/Township/Cantonment) : S. F. Nos. 99/25(99/2B1) & 100/5 (100/1A1 Classified as) 100/1A) Arcot Road, Painginar Village  
Cheyyur Taluk  
Tiruvannamalai District - 604407.
3. Year of construction : **Vide Annexure - II**
4. Approximates cost of construction as per current rate : Rs. 380.00 Lakhs
5. Purpose for which the building is being used or proposed to be used : Educational
6. Purpose for which the building has hitherto been used : Educational
7. Details of construction of the building (particulars of the foundation, soil, Specification of various parts under  
(i) Foundation : RCC Column & Isolated Footing  
(ii) Basement : RCC Column, Plinth Beam & Brick in CM  
(iii) Superstructure : RCC Column & Brick in CM  
(iv) Floor & Roof are to be given) : Flooring: Cement, Marble & Tiles  
Roof: RCC Slab
8. Period for which the license is require : May be issued from **01.06.2020 to 31.05.2023**  
(For Three years only)
9. Number of persons to be accommodated Refer "ANNEXURE" to this : **One Thousand Five Hundred (1500) Pupils only**

Place : Vellore

Date : 06.06.2020

Signature of the Correspondent

  
Signature of the Engineer


**Er. D. NATARAJAN, B.E.(CML) ME**  
Chartered Engineer  
Panel Engineer Class 1A  
Thiruvannamalai District  
# 400, Nethaji Bose 4th Street,  
Phase III, TNHB, Sathuvachary  
Vellore-632 009  
Cell: 94431 06470, 8056631312

மரம் வளர்ப்போம். மழை பெறுவோம்

**ANNEXURE TO "STATEMENT ACCOMPANYING FORM – A"**

Certified that no addition or alteration has been made to the existing building or portion of a building for which this application has been made. I undertake to obtain a fresh license in case any addition or alteration is made to the existing building or portion of the building. I also undertake to obtain a fresh license if the purpose for which the license was granted for the use of the building or portion of the building originally is change or altered subsequently.

This is further to certify that no thatched buildings are used for conducting any classes within the School premises. Any thatched building constructed/used after issue of this certificate, I would be held responsible for fire accident/mishap that may occur later and that I am aware that it is a punishable crime.

  
Signature of the Correspondent

CORRESPONDENT,  
WISDOM VIDHYASHRAM INTERNATIONAL SCHOOL  
Arcot Road, CHEYYAR-604407.


Er. D.NATARAJAN, B.E.(CIVIL),M.I.E.,  
CHARTERED ENGINEER  
REGISTERED & APPROVED ENGINEER  
BY THE BOARD OF ENGINEERS, TAMIL NADU.  
PANEL ENGINEER CLASS IA, THIRUVANNAMALAI DISTRICT

Res: 50-A,3<sup>rd</sup> Street, S.S.Nagar.  
Palanipet, Arakkonam – 631002  
Off: 400, Nethaji Bose 4<sup>th</sup> Street  
Phase III, TNHB, Sathuvachari  
Vellore – 632 009  
Cell: 9443106470, 8056631312  
Email: dnatarajan8@gmail.com

## ANNEXURE - II

### WISDOM VIDHYASHRAM INTERNATIONAL SCHOOL, PAINGINAR VILLAGE

S.No.	Name of the Building	Year of Construction	Age of the Building
1.	<b>NORTH SIDE BUILDING:</b>		
	Ground Floor : RCC	2005	15 Years
	First Floor : RCC	2006	14 Years
	Second Floor : RCC	2007	13 Years
2.	<b>SOUTH SIDE BUILDING:</b>		
	Ground Floor : RCC	2006	14 Years
	First Floor : RCC	2007	13 Years
	Second Floor : RCC	2008	12 Years
	Third Floor : RCC	2017	03 Years
3.	<b>EAST SIDE BUILDING:</b>		
	Ground Floor : RCC	2007	13 Years
	First Floor : RCC	2007	13 Years
	Second Floor : RCC	2008	12 Years

  
Er. D. NATARAJAN, B.E.(CIVIL) MIE  
Chartered Engineer  
Panel Engineer Class 1A  
Thiruvannamalai District  
# 400, Nethaji Bose 4th Street,  
Phase III, TNHB, Sathuvachary  
Vellore-632 009  
Cell: 94431 06470, 8056631312

Er. D.NATARAJAN, B.E.(CIVIL),M.I.E.,  
CHARTERED ENGINEER  
REGISTERED & APPROVED ENGINEER  
BY THE BOARD OF ENGINEERS, TAMIL NADU.  
PANEL ENGINEER CLASS IA, THIRUVANNAMALAI DISTRICT

Res: 50-A,3<sup>rd</sup> Street, S.S.Nagar.  
Palanipet, Arakkonam – 631002  
Off: 400, Nethaji Bose 4<sup>th</sup> Street  
Phase III, TNHB, Sathuvachari  
Vellore – 632 009  
Cell: 9443106470, 8056631312  
Email: dnatarajan8@gmail.com

FORM – B

**STATEMENT ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS**  
**WISDOM VIDHYASHRAM INTERNATIONAL SCHOOL, PAINGINAR VILLAGE**

FORM OF CERTIFICATE OF STRUCTURAL SOUNDNESS UNDER SUB SECTION (B) OF SECTION OF (4) OF SECTION 4 OF THE TAMIL NADU PUBLIC BUILDING ( LICENSING ACT 1965 TAMIL NADU ACT 1 OF 1965) REFERRED TO IN RULE OF THE TAMIL NADU PUBLIC (LICENSING) RULES 1966.

I Certify, that I have inspected the building mentioned in the statement and furnished below its salient technical features.

1. **Foundation:**


- |      |  |                   |
|------|--|-------------------|
| i.   | Depth below ground level                         | : 08 ft below G.L |
| ii.  | Nature of soil met out in the foundation         | : Hard Gravel     |
| iii. | Pressure at foundation                           | : 12 tones / Sq.m |
| iv.  | Probable safe bearing capacity of the foundation | : 18 tones / Sq.m |

2. **Superstructure:**

- |     |  |   |                               |
|-----|--|---|-------------------------------|
| i.  | Maximum stress in most critical Sections of masonry and concrete | a) R.C.C Concrete : 35 Kg / Sq. cm      | b) Masonry : 08 tones / Sq.m. |
| ii. | Nature of masonry and concrete                                   | : Brick masonry in cm: 30 tones / Sq.m. |                               |
|     | And its safe permissible stress                                  | R.C.C                                   | : 40 Kg / Sq.cm.              |

The Structural of the building has been verified by me with reference to ISIS loading standards 875 (Latest version) and other relevant Indian Standard code of practices I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. This Certificate does not include any Thatched sheds and also any flammable building material utility. Proper Toilet facilities to be provided as per norms. If any thatched sheds are found at a later period after issue of this certificate / License this certificate gets invalid. A license may be granted for the period from 01.06.2020 to 31.05.2023.

Signature of the Correspondent

  
Signature of the Engineer  
Er. D. NATARAJAN, B.E.(CIVIL) MIE  
Chartered Engineer  
Panel Engineer Class 1A  
Thiruvannamalai District  
# 400, Nethaji Bose 4th Street,  
Phase III, TNHB, Sathuvachary  
Vellore-632 009  
Cell: 94431 06470, 8056631312

மரம் வளர்ப்போம். மழை பெறுவோம்.

Er. D.NATARAJAN, B.E.(CIVIL),M.I.E.,  
CHARTERED ENGINEER  
REGISTERED & APPROVED ENGINEER  
BY THE BOARD OF ENGINEERS, TAMIL NADU.  
PANEL ENGINEER CLASS IA, THIRUVANNAMALAI DISTRICT

Res: 50-A,3<sup>rd</sup> Street, S.S.Nagar.  
Palanipet, Arakkonam – 631002  
Off: 400, Nethaji Bose 4<sup>th</sup> Street  
Phase III, TNHB, Sathuvachari  
Vellore – 632 009  
Cell: 9443106470, 8056631312  
Email: dnatarajan8@gmail.com

**FORM - C**

**STATEMENT ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS**

**WISDOM VIDHYASHRAM INTERNATIONAL SCHOOL, PAINGINAR VILLAGE**


Form of certificate of structural soundness under sub section (b) of section of 4 of the madras Public Buildings (Licensing Act 1963 Madras Act 13 of 1965 referred to in rule 4 of the Madras Public building (Licensing) rules 1977.

Certify that have inspected the building mentioned in the statement below and I have satisfied myself the building is structural sound to be used as a public building for the purpose note in the statement. The structural soundness of the building has been verified taking into account the loading as per latest Indian standard 875.

Location of the building door No. street name and name of the place	Age of the building	Value of the Building	No. of Storeys	Short Description of structure steel RCC framed or load bearing masonry
1.	2.	3.	4.	5.
<b>WISDOM VIDHYASHRAM INTERNATIONAL SCHOOL</b> Arcot Road, Painginar Village, Cheyyur Taluk Tiruvannamalai District - 604407.	Vide Annexure - II	Rs. 380.00 Lakhs	Vide Annexure - II	RCC Framed Structure

Purpose for which the building is certified for use	The Period for which the building will be structurally sound	No of the persons to be accommodated	Remarks
6.	7.	8.	9.
Educational	License may be issued for the period of Three Years from 01.06.2020 to 31.05.2023	1500 Pupils only	Building is structurally sound

Signature of the Correspondent

  
Er. D. NATARAJAN, B.E.(CIVIL) MIE  
Chartered Engineer  
Panel Engineer Class 1A  
Thiruvannamalai District  
# 400, Nethaji Bose 4th Street,  
Phase III, TNHB, Sathuvachary  
Vellore-632 009  
Cell: 94431 06470, 8056631312

மரம் வளர்ப்போம், மழை பெறுவோம்.

D.Dis.B3/ 2652 /2020

Taluk Office, Cheyyar

Date: 19.06.2020

**FORM-D**

FORM OF LICENCE UNDER SUB SECTION (1) OF SECTION 6 OF THE MADRAS PUBLIC BUILDING (LICENCING ACT 1965 (MADRAS ACT 13 CF OF 1965) REFERRED TO IN RULE 6 OF THE MADRAS PUBLIC BUILDING (LICENSING) RULES 1966.

**LICENCE**

Licence No. 01/2020

Fees Rs. 1000/-  
(one thousand only)

Chalan No.5

Date: 05.06.2020

State Bank of India

Cheyyar

Licence is hereby granted to THE CORRESPONDENT, WISDOM VIDYASHRAM INTERNATIONAL SCHOOL, ARCOT ROAD, PAINKINAR, Cheyyar Taluk, Tiruvannamalai District, Tamilnadu, Pin Code 604 407, for the purpose and in respect of the building specified in the statement below and subject to the conditions and for the period mentioned here under.

The period of validity of the Licence shall be 03 Years from  
01.06.2020 to 31.05.2023


*[Handwritten Signature]*  
Tahsildar,  
Cheyyar.

**STATEMENT TO ACCOMPANY THE LICENCE**

Location of the building (Door No. Street, No. and Name of the place)	Survery No.	Purpose for which the building is licenced to be used as a public building	Number of persons to be accommodated
(1)	(2)	(3)	(4)
Arcot Road, Painkinar Village, Cheyyar Taluk, Tiruvannamalai District, Tamilnadu, Pin Code 604 407.	S.NO.99/25 (99/2B1),100/5(10 0/1A1, Classified as 100/1A)	To run a school	1500 Students

TO,

THE CORRESPONDENT,  
WISDOM VIDYASHRAM  
INTERNATIONAL SCHOOL,  
CHEYYAR.



*[Handwritten Signature]*  
Tahsildar, 19/06/20  
Cheyyar.